

FES FOUUSER ENVIRONMENTAL SERVICES

165 Camden Avenue, Versailles, Ky. 40383 Phone: 859-873-6211 Fax: 859-873-3715 e-mail: lab@fouser.com

LABORATORY/CONSULTING

Certificate of Analysis

Highbridge Springs
Mrs. Linda Slagel
P.O. Box 100
Wilmore, KY 40390-0100

Project: Complete Secondary Analysis
Entered By: Lynn Ellis
Date Reported: 2/24/2010
Date Received: 2/2/2010
Date Complete: 2/23/2010

Test	Method	Result	Units	PQL	Date	Analyst
906618-01	Drinking		2/2/10 15:00			
Secondary Analyses						
Aluminum, Al	EPA 200.7	<0.050	mg/L	0.05	2/15/2010	CB
Chloride	EPA 300.0	<1.00	mg/L	1	2/8/2010	EW
Copper, Cu	EPA 200.7	<0.010	mg/L	0.01	2/15/2010	CB
Fluoride, F	EPA 300.0	0.52	mg/L	0.5	2/8/2010	EW
Iron, Fe	EPA 200.7	<0.010	mg/L	0.01	2/15/2010	CB
Manganese, Mn	EPA 200.7	<0.010	mg/L	0.01	2/15/2010	CB
Silver, Ag	EPA 200.7	<0.0025	mg/L	0.0025	2/15/2010	CB
Sulfate	EPA 300.0	<1.00	mg/L	1	2/8/2010	EW
Zinc, Zn	EPA 200.7	<0.010	mg/L	0.01	2/15/2010	CB
Color	EPA 110.2	<10	Pt-Co	10	2/3/2010	KM
Langlier Index	SM 2330 B	-4.22	S.I.		2/23/2010	CB
Odor	SM 2150 B	<1	T.O.N.	1	2/3/2010	KM
pH	SM 4500 H+B	5.81	S.U.		2/2/2010	RF
Total Dissolved Solids	SM 2540 C	<10	mg/L	10	2/7/2010	KM
MBAS	SM 5540 C	<0.03	mg/L	0.03	2/4/2010	KM
Temperature	SM 2550 B	18.3	°C		2/2/2010	RF
Alkalinity	SM 2320 B	<10	mg/L as CaCO ₃	10	2/10/2010	CT
Hardness, Ca	SM 2340 B	4.42	mg/L as CaCO ₃	0.2497	2/15/2010	CB
Calcium, Ca	EPA 200.7	1.77	mg/L	0.1	2/15/2010	CB

Approved By: _____

Ray Fouser, P.E.