

# FES FOUUSER ENVIRONMENTAL SERVICES

165 Camden Avenue, Versailles, Ky. 40383 Phone: 859-873-6211 Fax: 859-873-3715 e-mail: lab@fouser.com

LABORATORY/CONSULTING

## Certificate of Analysis

Highbridge Springs  
Mrs. Linda Slagel  
P.O. Box 100  
Wilmore, KY 40390-0100

Project: Inorganic Analysis  
Entered By: Lynn Ellis  
Date Reported: 2/25/2010  
Date Received: 2/2/2010  
Date Complete: 2/25/2010

Test	Method	Result	Units	PQL	Date	Analyst
<b>906619-01</b>	<b>Drinking</b>		<b>2/2/10 15:00</b>			
Inorganic Analyses						
Antimony, Sb	EPA 200.9	<0.002	mg/L	0.002	2/23/2010	CB
Arsenic, As	EPA 200.9	<0.002	mg/L	0.002	2/22/2010	CB
Barium, Ba	EPA 200.7	<0.010	mg/L	0.01	2/15/2010	CB
Beryllium, Be	EPA 200.9	<0.00025	mg/L	0.00025	2/23/2010	CB
Cadmium, Cd	EPA 200.7	<0.0025	mg/L	0.0025	2/15/2010	CB
Chromium, Cr	EPA 200.7	<0.010	mg/L	0.01	2/15/2010	CB
Cyanide, Total	SM 4500-CN E	<0.010	mg/L	0.01	2/15/2010	KM
Fluoride, F	EPA 300.0	0.51	mg/L	0.5	2/8/2010	EW
Mercury, Hg	EPA 245.1	<0.0001	mg/L	0.0001	2/25/2010	CB
Nickel, Ni	EPA 200.7	<0.010	mg/L	0.01	2/15/2010	CB
Selenium, Se	EPA 200.9	<0.002	mg/L	0.002	2/23/2010	CB
Thallium, Tl	EPA 200.9	<0.002	mg/L	0.002	2/22/2010	CB

Approved By: \_\_\_\_\_

Ray Fouser, P.E.